



Product Service

CERTIFICATE

No. Z10 17 03 72237 110

Holder of Certificate: Shenzhen INVT Electric Co., Ltd.No.4 Building, Gaofa Industrial Park
Longjing, Nanshan District

518055 Shenzhen

PEOPLE'S REPUBLIC OF CHINA

Factory(ies):

96972

Certification Mark:**Product:**

Safety components

Model(s):Goodrive GD20 (see nomenclature)
EC-FS101-24**Parameters:**

Indoor installation

Temperature range:

-10°C ~ +50°C

Humidity:

Below 90% RH

Altitude:

Below 2000m

Ple (d), CAT3 SIL3 (2)

depending from model
(see nomenclature)**Tested according to:**

EN 61800-5-1:2007

EN 61800-5-2:2016

IEC 61800-5-1(ed.2)

IEC 61800-5-2(ed.2)

EN 61508-1:2010

EN 61508-2:2010

IEC 61508-1(ed.2)

IEC 61508-2(ed.2)

EN 62061:2005/A2:2015

IEC 62061(ed.1);am1;am2

EN ISO 13849-1:2015

ISO 13849-1:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

SS90809T

Valid until:

2022-04-06

Date, 2017-04-07
(Guido Neumann)

Page 1 of 3